

Chapter 12. Stormwater Regulations

§ 12-7. RESURFACING OF EXISTING PARKING AREAS AND DRIVEWAYS.

#10

§ 12-7.1. Purpose.

[Ord. No. 266-10 § 2]

This section requires the retrofitting of existing storm drain inlets which are in direct contact with repaving, repairing, reconstruction, or resurfacing or alterations of facilities on private property, to prevent the discharge of solids and floatables (such as plastic bottles, cans, food wrappers and other litter) to the municipal separate storm sewer system(s) operated by the Township of Long Hill so as to protect public health, safety and welfare, and prescribes penalties for the failure to comply. In order to facilitate the upgrading of storm drain inlets, the Township will maintain a list of suppliers in the area which keep inlet grates and compliant ECO heads in stock.

§ 12-7.2. Definitions.

[Ord. No. 266-10 § 2]

For the purpose of this section, the following terms, phrases, words, and their derivations shall have the meanings stated herein unless their use in text of this section clearly demonstrates a different meaning. When not inconsistent with the context, words used in the present tense include the future, words used in the plural number include the singular number, and words used in the singular number include the plural number. The word "shall" is always mandatory and not merely directory.

MUNICIPAL SEPARATE STORM SEWER SYSTEM (MS4)

Shall mean a conveyance or system of conveyances (including roads with drainage systems, municipal streets, catch basins, curbs, gutters, ditches, man-made channels, or storm drains) that is owned or operated by Long Hill Township or other public body, and is designed and used for collecting and conveying stormwater.

PERSON

Shall mean any individual, corporation, company, partnership, firm, association, or political subdivision of this State subject to municipal jurisdiction.

STORM DRAIN INLET

Shall mean an opening in a storm drain used to collect stormwater runoff and includes, but is not limited to, a grate inlet, curb-opening inlet, slotted inlet, and combination inlet.

WATERS OF THE STATE

Shall mean the ocean and its estuaries, all springs, streams and bodies of surface or ground water, whether natural or artificial, within the boundaries of the State of New Jersey or subject to its jurisdiction.

§ 12-7.3. Prohibited Conduct.

[Ord. No. 266-10 § 2]

No person in control of private property (except a residential lot with one single-family house) shall authorize the repaving, repairing (excluding the repair of individual potholes), resurfacing (including top coating or chip sealing with asphalt emulsion or a thin base of hot bitumen), reconstructing or altering any surface that is in direct contact with an existing storm drain inlet on that property unless the storm drain inlet either:

- a. Already meets the design standard below to control passage of solid and floatable materials; or
- b. Is retrofitted or replaced to meet the standard in subsection 12-7.4d below prior to the completion of the project.

§ 12-7.4. Design Standard.

[Ord. No. 266-10 § 2]

Storm drain inlets identified in subsection 12-7.3 above shall comply with the following standard to control passage of solid and floatable materials through storm drain inlets. For purposes of this paragraph, solid and floatable materials means sediment, debris, trash, and other floating, suspended, or settleable solids. For exemptions to this standard see subsection 12-7.4c.

- a. Property owners shall use either of the following grates whenever they use a grate in pavement or another ground surface to collect stormwater from that surface into a storm drain or surface water body under that grate:
 1. The New Jersey Department of Transportation (NJDOT) bicycle safe grate, which is described in Chapter 2.4 of the NJDOT Bicycle Compatible Roadways and Bikeways Planning and Design Guidelines (April 1996); or
 2. A different grate, if each individual clear space in that grate has an area of no more than seven square inches, or is not greater than 0.5 inches across the smallest dimension.
Examples of grates subject to this standard include grates in grate inlets, the grate portion (non-curb-opening portion) of combination inlets, grates on storm sewer manholes, ditch grates, trench grates, and grates of spacer bars in slotted drains. Examples of ground surfaces include surfaces of road (including bridges), driveways, parking areas, bikeways, plazas, sidewalks, lawns, fields, open channels, and stormwater basin floors.
- b. Whenever property owners use a curb-opening inlet, the clear space in that curb opening (or each individual clear space, if the curb opening has two or more clear spaces) shall have an area of no more than seven square inches, or be no greater than two inches across the smallest dimension.
- c. This standard does not apply:
 1. Where the Municipal Engineer agrees that this standard would cause inadequate hydraulic performance that could not practicably be overcome by using additional or larger storm drain inlets that meet these standards;
 2. Where flows are conveyed through any device (e.g., end of pipe netting facility, manufactured treatment device, or a catch basin hood) that is designed, at a minimum, to prevent delivery of all solid and floatable materials that could not pass through one of the following:
 - (a) A rectangular space 4 5/8 inches long and 1 1/2 inches wide (this option does not apply for outfall netting facilities); or
 - (b) A bar screen having a bar spacing of 0.5 inches.
 3. Where flows are conveyed through a trash rack that has parallel bars with one inch spacing between the bars; or
 4. Where the New Jersey Department of Environmental Protection determines, pursuant to the New Jersey Register of Historic Places Rules at N.J.A.C. 7:4-7.2(c), that action to meet this standard is an undertaking that constitutes an encroachment or will damage or destroy the New Jersey Register listed historic property.

§ 12-7.5. Enforcement.

[Ord. No. 266-10 § 2]

This section shall be enforced by the Long Hill Township Engineering Department or any person(s) designated by the Township Administrator to perform such inspections for the Township. These person(s) can be, but are not limited to, the Zoning Officer, the Code Enforcement Officer, Department of Public Works Superintendent and Building Code Official.

§ 12-7.6. Penalties.

[Ord. No. 266-10 § 2]

Any person(s) who is found to be in violation of the provisions of this section shall be subject to one warning. For each subsequent violation, the penalty shall be in accordance with Section 1-5 of the Revised General Ordinances of the Township of Long Hill. Each storm drain inlet that is not retrofitted to meet the design standard shall be considered a separate offense.