

TOWNSHIP OF LONG HILL FIRE PREVENTION BUREAU

CERTIFICATE OF SMOKE DETECTOR AND CARBON MONOXIDE ALARM AND PORTABLE FIRE EXTINGUISHER COMPLIANCE

N.J.A.C 5:70-2.3 REQUIREMENTS FOR THE INSTALLATION OF SMOKE AND CARBON MONOXIDE DETECTORS IN ONE AND TWO FAMILY DWELLINGS

1. All smoke detectors shall bear a label showing the detector has been tested in accordance with Underwriters Laboratories Standard 217.
2. All smoke detectors shall be either battery operated or permanently wired to a non-switchable circuit of the house current. Plug in cord connected units are permitted if a restraining device is used at the plug-in and the outlet is not controlled by a wall switch.
3. All equipment shall be installed in a workmanlike manner.
4. All equipment shall be so located that accidental activation will not be caused by jarring or vibration. ***No Double sided tape is permitted to be used for mounting equipment.**
5. All equipment shall be affixed to the wall or ceiling surface in accordance with the manufacturer's recommendations.
6. At least one smoke detector shall be installed on each level of the dwelling. If there are separate sleeping areas on any level, additional detectors are required in the immediate vicinity of each separate sleeping area. (Within 10 feet)
7. The preferable location for smoke detectors is on the center of the ceiling. Where this is impractical, wall mounting is acceptable. Ceiling mounted detectors shall be at least 4 inches from any side wall or other downward projection. For wall mounted units the top of the detector shall be within 4 and 12 inches of the ceiling.
8. Smoke detectors in room with ceiling sloped greater than 1 foot rise per 8 feet horizontal shall be located at the high side of the room.
9. Smoke detectors are not to be installed in stairways.
10. A smoke detector installed in the basement or to protect a level without a separate sleeping area shall be located in close proximity to the stairway leading to the floor above.
11. Smoke detectors installed to protect a separate sleeping area shall be installed outside of, but in the immediate vicinity of, the sleeping area. (Within 10 feet)
12. Smoke detectors are not required in crawl spaces or in unfinished attic spaces.

Revised 7/07

SMOKE DETECTOR PLACEMENT LAW

- BASEMENT:** One at the bottom of the stairs to first floor.
One within 10' of a bedroom (if any).
- FIRST FLOOR:** One at the bottom of the stairs to second floor.
One within 10' of a bedroom (if any).
- SECOND FLOOR:** One at the top of the stairs from first floor.
One within 10' of a bedroom (if any).
- THIRD FLOOR:** One at the top of the stairs from the second floor.
One within 10' of a bedroom (if any).
- ATTIC:** No detector needed if the attic is not finished.

PORTABLE FIRE EXTINGUISHER

1. The extinguisher must be located within 10 feet of the kitchen;
2. The top of the extinguisher must not be more than 5 feet above the floor;
3. The extinguisher must be visible and in a readily accessible location free of from being blocked by furniture, storage, or other items;
4. The extinguisher must be near a room exit or travel path that provides an escape route to the exterior;
5. At least one portable fire extinguisher shall be installed in all one and two family dwellings (except seasonal rental units) upon change of occupancy;
6. The extinguisher shall be listed, labeled, charged and operable;
7. The size shall be no smaller than 2A:10B:C, rated for residential use and weigh no more than 10 pounds;
8. The hangers or brackets supplied by the manufacturer must be used;
9. The extinguisher must be accompanied by an owner's manual or written information regarding the operation, inspection, and maintenance of the extinguisher; and
10. The extinguisher must be installed with the operating instructions clearly visible.

New extinguishers are not required to be serviced or tagged, as long as the seller or agent can provide proof of purchase or receipt.

Certificate valid for 6 months from date of issue.

CARBON MONOXIDE DETECTOR PLACEMENT

*Detectors must be installed outside of the bedroom or sleeping area, within 10' of bedroom doors.

CARBON MONOXIDE ALARMS

2-1.1.1

Carbon monoxide alarms or detectors should be installed in any family living unit containing fuel-burning appliances or fireplace or having an attached garage.

2-1.1.2

A carbon monoxide alarm or detector should be centrally located outside of each sleeping area in the immediate vicinity of the bedrooms. Where bedrooms are separated and the audibility of the alarm or the detector to occupants within the bedroom area could be seriously impaired, more than one unit could be needed. Each alarm or detector should be located on the wall, ceiling, or other location as specified in the installation instructions that accompany the unit.

***DETECTORS MUST BE INSTALLED OUTSIDE OF THE BEDROOM OR SLEEPING AREA, WITHIN 10' OF BEDROOM DOORS.**

2-1.2

Each alarm should cause the operation of an alarm notification appliance that should be clearly audible in all bedrooms over background noise levels and with all intervening doors closed.

2-1.3

In a household occupied by one or more hearing impaired persons, each initiating device should cause the operation of a visible alarm signal(s) in accordance with 2-3.2.3

NOTE: Dwellings with existing fire detection and carbon monoxide systems installed through the building department (new construction/renovation and a certificate of occupancy was issued) must be maintained to the same level of the certificate of occupancy upon resale/lease. Any portion of an existing system not serviceable or repairable shall be replaced. *Battery operated smoke detectors are not acceptable replacements. *Appointments are scheduled every 30 minutes – If the owner or agent is late the appointment must be rescheduled and is subject to a higher permit fee!

Certificate valid for 6 months from date of issue.

**CERTIFICATE OF SMOKE DETECTOR AND CARBON MONOXIDE
ALARM AND FIRE EXTINGUISHER COMPLIANCE FEE:**

RECEIVED more than 10 business days = \$50.00

RECEIVED four to ten business days =\$70.00

RECEIVED fewer than four business days=\$125.00

Appointments are scheduled based upon availability:

To schedule an appointment please call: 908-647-8000 x 210

NOTE: Dwellings with existing fire detection and carbon monoxide systems installed through the building department (new construction/renovation and a certificate of occupancy was issued) must be maintained to the same level of the certificate of occupancy upon resale/lease. Any portion of an existing system not serviceable or repairable shall be replaced. *Battery operated smoke detectors are not acceptable replacements. *Appointments are scheduled every 30 minutes – If the owner or agent is late the appointment must be rescheduled and is subject to a higher permit fee!

Certificate valid for 6 months from date of issue.





Figure A-2-5.2.1(c) A smoke detector should be located on each story.
 [From NFPA 74, Figure B-2.1.3]



NOTE: Measurements shown are to the closest edge of the detector.
 Figure A-2-5.2.2(b) Example of proper mounting for detectors.
 [From NFPA 74, Figure B-3.2.1]




Figure A-2-5.2.1(a) A smoke detector should be located between the sleeping area and the rest of the family living unit.
 [From NFPA 74, Figure B-2.1.1]

(b) *Where to Locate the Required Smoke Detectors in New Construction.* All of the smoke detectors specified in (a) for existing construction are required, and, in addition, a smoke detector is required in each bedroom.