DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/13/10

TIME: 7:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-03-13 1507-27

OPERATOR # 28

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

High flow Due To Heavy RAINFALL - Sand Filters Taken off Line

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/14/10

TIME: _____ AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzinski

DEP HOT LINE:

CASE # 10-03-14 1726-11

OPERATOR # 39

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Flow Continued To increase - Took Oxidation Ditches off Line (Rotors off) To Avoid Solids washout. Preliminary Treatment, Post Aeration & Disinfection Continued.

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/21/10

TIME: 9:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-03-21 0926-36

OPERATOR # 34

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

flow decreased to point of operation - oxidation Ditch Rotors put back on line

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/23/10

TIME: 7:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-03-23 0710

OPERATOR # 17

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Flows increased Again To To following Storm - Put Rotors on Timer To Contain Biomass within System

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/24/10

TIME: 11:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-03-24 112200

OPERATOR # 330

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Sand filters were Put Back on Line

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: ~~[illegible]~~ 9/10/10

TIME: 9:53 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-09-10 0948 54

OPERATOR # 25

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Found Ox Ditch #2 No. Side Speed Reducer Siezed. Raised water Level in Tank To increase Oxygen & Began Repair Operations.

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 9/22/10

TIME: 7:00 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-09-22 1918 09

OPERATOR # 28

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Repair To Ox Ditch #2 No. Side Completed - Back on Line.

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/01/10

TIME: 3:30 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-12-01-1534-28

OPERATOR # 28

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Passed Sand filters Due To High flows from heavy Rainfall

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/2/10

TIME: 11:12 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 10-12-02-1111-46

OPERATOR # 33

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Sand Filters Back on Line

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/25/11

TIME: 11:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 1102 25 11 1737

OPERATOR # 33

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Took Sand filters off Line Due To High Flows
Peaked at 4.2 at 11:00am.

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRELEMS

DATE REPORTED: 3/2/11

TIME: 6:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 1103 02 070314

OPERATOR # 42

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Sand filters Back on line

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/6/11

TIME: 9:48 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 110306 2152 50

OPERATOR # 18

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Took Sand Filters off Line

2.25" Rain Recorded

REPORTED BY: Mario Bonaccorso

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/8/11

TIME: 3:24 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzinia

DEP HOT LINE:

CASE # 11-03-08-1416-15

OPERATOR #

LOCATION OF INCIDENT: Mountain Ave No. of RR Tracks

DESCRIPTION OF INCIDENT:

Surging Man Hole - Due To Pump Station On Mollistown Rd Cannot Handle The Flow Due To Rain Fall ~~[illegible]~~ 3/6 - 3/7/11

Bill Charlton from Morris County Hazmat Cell # 973-418-2540

REPORTED BY: Mario B + Bill Charlton from M.C. Hazmat.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/11/11

TIME: 9:19 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 11 03 11 09 19 31

OPERATOR #

LOCATION OF INCIDENT: 300 ft No of RR Tracks MR 213

DESCRIPTION OF INCIDENT:

Surging Man Hole Heavy Rain Flooding
Approx 25 - 50 GPM

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/11/11

TIME: 9:24 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11 03 11 0924 25

OPERATOR # 42

LOCATION OF INCIDENT: Mt Ave 600 ft So. Castle Pl. MR

DESCRIPTION OF INCIDENT:

surging MH <5 gpm

REPORTED BY: MARIO B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/11/11

TIME: 9:27 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11 03 11 0927 30

OPERATOR # 42

LOCATION OF INCIDENT: Bungalow Terr + Old Forge Rd.

DESCRIPTION OF INCIDENT:

Surging MH < 5 GPM

REPORTED BY: Mark B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/11/11

TIME: 9:29 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 1103 11 0929 59

OPERATOR # 42

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

~~Flow~~ Instantanious Flow over 4 mgD - Plant Can not Handle Hydraulically - Put No. Rotors on oxditches on Times - To Help Sustain Bio mass within The Treatment System - Sand filters Still off Line -

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/14/11

TIME: 8:40 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11 0314 0855 32

OPERATOR # 42

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Sand Filters Back on Line - Both Rotors on Oxidation Ditches Back Working

REPORTED BY: _____

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/14/11

TIME: 7 30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11 03 14 08 57 32

OPERATOR # 42

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put oxidation Ditch Rotors Back on line Full Previously on Timer (No. Side)

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/15/11

TIME: 9:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11-04-15-0931-14

OPERATOR # 16

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

A message was left on my answering from Garden St. Labs That The fecal Coliform for wed 4/13/2011 was at 3600. Checked UV system - log for That DAY - All Racks & Bulbs were operational. found Algae Build up At Head of Racks - could Have caused Bad Sample

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/17/11

TIME: 3:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzinn

DEP HOT LINE:

CASE # 1104-1703234 4

OPERATOR # 35

LOCATION OF INCIDENT: Trentmont Pl.

DESCRIPTION OF INCIDENT:

Shutdown Aerators
By Passed Sand filters
Flow at 4.01 mgD

REPORTED BY: Robert Brooks

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/18/11

TIME: 11:50 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Nudzina

DEP HOT LINE:

CASE # 11-04-18-1311 54

OPERATOR # 25

LOCATION OF INCIDENT: Treatment Plan

DESCRIPTION OF INCIDENT:
Put Sand filters Back on Line

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/14/11

TIME: 330 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11-08-14 1536 17

OPERATOR # 39

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Passed Sand Filters

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/16/11

TIME: 11:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11-08-16-1107-02

OPERATOR # 16

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Sand filter Back on line 9:00AM

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8-28-11

TIME: 2:37 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 11-08-28-0237-16

OPERATOR # ~~MARIO B.~~

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Passed Sand filter

Shut Down ovesef of Rotors

REPORTED BY: MARIO B

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 9/12/11

TIME: 7:27 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hedzing

DEP HOT LINE:

CASE # 11-09-12 0727 ~45

OPERATOR # 25

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put sand filters on line.

All Rotors operating since 9/10/11

9/11/11 - Eff cleaning up.

REPORTED BY: Mario B

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/23/11

TIME: 5:10 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzins

DEP HOT LINE:

CASE # 11-11-23 0514 11

OPERATOR # 15

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Passed Sand filters - Heavy Rain - High Flow

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/25/11

TIME: 6:45 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 11 11 25 065733

OPERATOR # 15

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put Sand Filters on Line

Put All Rotors on Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/8/11

TIME: 1:45 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 111208012246

OPERATOR # 39

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BYPASSED SAND FILTERS

REPORTED BY: BOB BROOKS

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/12/11

TIME: 10:05 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # Re 11120801424 6 / 11-12-12 1009-15

OPERATOR # 35

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BACK ONLINE AT 9:50 AM

REPORTED BY: BOB BROOKS

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/4/12

TIME: 11:15 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 12-06-04 1115 49

OPERATOR # 34

LOCATION OF INCIDENT: 118 Gillette Rd.

DESCRIPTION OF INCIDENT:

Leaking force main - 6" - under Repair By Hoff Bros.

REPORTED BY: Mario B.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/31/2012

TIME: 8:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 1210-31-0804-49

OPERATOR # 50

LOCATION OF INCIDENT: Cloverhill PS.

DESCRIPTION OF INCIDENT:

Generator Blew main seal - Running intermittently
Checking oil + Adding as needed - Advising Directors
To Have it monitored constantly During operation

State Says No Generators Are Available -
Looking into By Pass Pump. Berkeley Heights WWTP
Lent us there By Pass pump in case of generator failing

REPORTED BY: Mario B.

Fuel is a Problem - Asked Local OEM To Contact
County OEM To Stress The need for fuel

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11-10-12

TIME: 4:55 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 12-11-10-1652-57

OPERATOR # 42

LOCATION OF INCIDENT: SKYLINE DRIVE PUMP STATION

DESCRIPTION OF INCIDENT:

SKYLINE BACK UP GENERATOR STOPPED OPERATING RICH DESCH WAS ON DUTY CALLED KEVIN LYNN FOR ASSISTANCE AND WAS ABLE TO GET GENERATOR BACK ON LINE BY 6:15pm 11-10-12 THERE WERE NO SEWER OVERFLOWS. CALLED D.E.P to REPORT GENERATOR WAS BACK IN SERVICE AT 6:15pm CASE # 12-11-10-1813-29 · OPERATOR #42

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12-21-12

TIME: 7:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: mike

DEP HOT LINE:

CASE # 121221073337

OPERATOR # 50

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Bypass Sandfilters Due to Heavy Flow

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12-23-12

TIME: 8:40 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: mike

DEP HOT LINE:

CASE # 1212230843-50

OPERATOR # 34

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Sand filters put BACK on Line.

REPORTED BY: Vinny Tesin.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12-27-12

TIME: 7:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 121227071342

OPERATOR # 39

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Due to Heavy Rain Bypassed Sandfilters.

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12-28-12

TIME: 9:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 12122809/554

OPERATOR # 50

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Sandfilters back on line.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6-7-13

TIME: 6:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 130607181601

OPERATOR # 58

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BY-PASSED SAND FILTERS DUE TO HEAVY FLOW

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/15/13

TIME: 8:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 130615201704

OPERATOR # 62

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put SAND FILTERS BACK ON LINE

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/27/13

TIME: 6:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 1311270602 44

OPERATOR # 29

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: BY-PASSED SAND FILTERS DUE TO HEAVY FLOW. 2.08 INCHES OF RAINFALL

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/30/13

TIME: 8:07 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 131130080950

OPERATOR # 18

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

put sand filters Back on Line.

REPORTED BY: _____

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/29/13

TIME: 7:58 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 131229200307

OPERATOR # 64

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Bypass Sand filters Due to Heavy Rain
1.10 Inches Rain

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/31/13

TIME: 6:10 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE: CASE # 131231061552

OPERATOR # 29

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SANDFILTERS BACK ON-LINE

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/6/2014

TIME: 2:10 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 140106141402

OPERATOR # 25

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By-Passed Sand Filter Due to Heavy Rainfall + Snow melt

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/7/14

TIME: 6:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 1401070627 04

OPERATOR # 29

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK ON-LINE

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/6/14

TIME: 10:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HADZINA

DEP HOT LINE:

CASE # 1402061030-28

OPERATOR # 34

LOCATION OF INCIDENT: New Vernon Road P.S.

DESCRIPTION OF INCIDENT:

Both pumps At 2:00pm on 2/4/14 went down on Electrical failure. Called Pumping Services to Bring A Diesel By-pass pump They had it installed By 8:00pm on 2/4/14

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/6/14

TIME: 10:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 10402061036-20

OPERATOR # 34

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Clarifier #1 Went Down For mechanical problem on 2/4/14 at 8:00 A.M. Drained TANK on 2/4/14 and made Repairs on 2/6/14 AT 10:00 AM Broken Shear pin

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/6/14

TIME: 1:00 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: EO HUDZINA

DEP HOT LINE:

CASE # 140206132031

OPERATOR # 58

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

put Clarifier #1 BACK on-Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/8/14

TIME: 5:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 1402081726-20

OPERATOR # 65

LOCATION OF INCIDENT: NEW VERNON RD P.S.

DESCRIPTION OF INCIDENT:

PUT STATION BACK ON LINE AT 3:00 pm ON 2/7/14 &
TOOK STATION OFF OF BY-PASS

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/9/14

TIME: 10:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HODZINA

DEP HOT LINE:

CASE # 140209100855

OPERATOR # 62

LOCATION OF INCIDENT: New Vernon RD P.S.

DESCRIPTION OF INCIDENT:

Pkt pump station on By-Pass at 8:00AM pump #1

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/18/14

TIME: 9:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 140218103934

OPERATOR # 33

LOCATION OF INCIDENT: New Vernon RD P.S.

DESCRIPTION OF INCIDENT:

put pump station BACK on Line Took it off the By-pass pump

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/23/14

TIME: 6:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 1402231821-43

OPERATOR # 63

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BY-PASSED SAND FILTERS

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2-24-14

TIME: 2:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 14022414247

OPERATOR # 59

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SANDFILTERS BACK ON-LINE.

REPORTED BY: Vinny TESTA

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/13/14

TIME: 6:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 1403130745 57

OPERATOR # 18

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

By Passed Sand Filters Due to High Flow From Rainfall & Snow Melt

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/15/14

TIME: 2:45 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 1403151500330

OPERATOR # 65

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: Put SAND FILTERS BACK ON-LINE

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/30/14

TIME: 5:50 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 140330055513

OPERATOR # 65

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Pass Sand filters Due to High Flow from Rain Fall - 2" rain

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/31/14

TIME: 7:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 140331082218

OPERATOR # 58

LOCATION OF INCIDENT: MOUNTAIN AVE Gillette NJ 07933

DESCRIPTION OF INCIDENT:

Surging MAN-Hole on Mountain Ave in Sidewalk estimated gallons per minute 20-40 gallons water is RAW Sewage but mostly clean. will Clean area as soon as the MAN-Hole stops surging. Reason for surging MAN-Hole is Due to Heavy RAINFALL of over 2.5 Inches. The pump station is working but can't Handle all the Heavy flow.

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/1/14

TIME: 7:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: EO HUDZINA

DEP HOT LINE:

CASE # 140401080003

OPERATOR # 25

LOCATION OF INCIDENT: Mountain AVE Gillette NJ 07933

DESCRIPTION OF INCIDENT:

Surging MAN-HOLE STOPPED Surging ON Mountain AVE North of Railroad Tracks ON Left side of ROAD. Will do Clean up Today

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/3/14

TIME: 1:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hodzina

DEP HOT LINE:

CASE # 14040313318

OPERATOR # 34

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
Put Sand Filters Back on-Line

REPORTED BY: [illegible]

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/30/14

TIME: 2:30 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 140430143720

OPERATOR # 25

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

By-passed sand filters due to heavy rainfall

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/1/14

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 14050107 5357

OPERATOR # 66

LOCATION OF INCIDENT: Gillette & Millington

DESCRIPTION OF INCIDENT:

1- Surging Man Hole Mountain Ave North of Railroad Tracks Gillette NJ 20-gallons per minute

2- Surging Man Hole Bungalow Tear & Old Forge Road Millington NJ 10-gallons per minute

The Time of incidents was found at 7:00 A.M.

Will Clean Area when Man-Holes Stop Surging

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/3/14

TIME: 4:14 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 140505091755

OPERATOR # 34

LOCATION OF INCIDENT: Millington NJ

DESCRIPTION OF INCIDENT:

Surging manhole Bungalow Ave stopped - AT 3:30PM
Will Clean AREA

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/5/14

TIME: 8:55 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 1405050857-10

OPERATOR # 34

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

put SAND filters BACK ON-LINE AT 8:45 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/6/14

TIME: 8:55 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 140505091146

OPERATOR # 34

LOCATION OF INCIDENT: Gillette NJ

DESCRIPTION OF INCIDENT:

Mountain Ave North of Railroad Tracks stopped surging at 8:00 AM. Will clean area

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/25/14

TIME: 10:11 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 140825220916

OPERATOR # C4

LOCATION OF INCIDENT: New Vernon Road Pump Station

DESCRIPTION OF INCIDENT:
Pump failure had to put pump station on By-pass Pumping Services installed By-pass pump.

REPORTED BY: Mike Mauro

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 9/4/14

TIME: 12:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 140904123415

OPERATOR # 16

LOCATION OF INCIDENT: New Vernon Road Pump Station

DESCRIPTION OF INCIDENT:

Took Pump Station off of By-Pass on 8/29/14 11:00 AM and Reinstalled Repaired pump

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/2/14

TIME: 10:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 141002100321

OPERATOR # 33

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
Took Clarifier #1 off-line at 6:00 AM
for Maintenance & Repair

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/3/14

TIME: 1:15 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 141003130955

OPERATOR # 59

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put Clarifier #1 BACK-ON-LINE AT 1:00pm

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/9/14

TIME: 7:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 14-12-09-0712-56

OPERATOR # 16

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BY PASSED SAND FILTERS DUE TO HEAVY RAINFALL

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/11/14

TIME: 7:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 14-12-11-07-2638

OPERATOR # 33

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK ON-LINE

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/18/14

TIME: 12:15 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 14-12-18-1225-13

OPERATOR # 34

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Doing Maintenance/Repair on Clarifier #2 at The Treatment Plant

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/19/14

TIME: 11:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 14-12-19-1144-26

OPERATOR # 68

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Clarifier #2 Back on-Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/18/15

TIME: 4:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-01-18-1641-38

OPERATOR # 35

LOCATION OF INCIDENT: TREATMENT plant

DESCRIPTION OF INCIDENT:
BY Passed Sand filters Due to
Heavy RAINFALL

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/20/15

TIME: 8:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-01-20-0919-38

OPERATOR # 44

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put Sand filters Back on-Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/12/15

TIME: 6:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 15-03-12-0605-35

OPERATOR # 69

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Passed Sand Filters Due High Flow From Snow Melt & Rain

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/17/15

TIME: 7:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 15-03-17-0930-44

OPERATOR # 34

LOCATION OF INCIDENT: TREATment Plant

DESCRIPTION OF INCIDENT:

Inner Bearing on Oxidation Ditch #1 Northside Rotor is Broken. Waiting for Quotes for it to Be Repaired

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/19/15

TIME: 12:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 15-03-19-1243-41

OPERATOR # 33

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
Put Sand Filters Back on-line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/23/15

TIME: 9:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HADZINA

DEP HOT LINE:

CASE # 15-03-23-0913-05

OPERATOR # 58

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Tow Clarifier #1 off-line for repair/maintenance

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/25/14

TIME: 2:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-03-25-1429-48

OPERATOR # 27

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

PUT Chamber #1 BACK ON-line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/26/15

TIME: 8:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HADZINA

DEP HOT LINE:

CASE # 15-03-26-0835-39

OPERATOR # 25

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Oxidation Ditch #1 Back on-Line North Side Rotor

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/20/15

TIME: 2:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-04-20-1429-54

OPERATOR # 34

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BY PASSED SAND FILTERS DUE to HEAVY RAIN FALL

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/21/15

TIME: 7:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HADZINA

DEP HOT LINE:

CASE # 15-04-21-0710-34

OPERATOR # 33

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK ONLINE

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/1/15

TIME: 2:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 15-06-01-1427-21

OPERATOR # 44

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
By-Passed Sand filters Due to Heavy Rainfall

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/2/15

TIME: 9:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-06-02-0920-26

OPERATOR # 34

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put Sand Filters Back on-Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 9/30/15

TIME: 9:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-09-30-0945-16

OPERATOR # 58

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
By-Passed Sand Filters Due to Heavy Rainfall

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/1/15

TIME: 2:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-09-30-0945-16

OPERATOR # 58

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put Sand Filters BACK ON-LINE AT 2:15pm

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/29/15

TIME: 6:00 (AM) PM Called 8:00 AM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-10-29-0802-32

OPERATOR # 160

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BY PASSED SAND FILTERS DUE TO HEAVY RAIN FALL AT 6:00 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/30/15

TIME: 11:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 15-10-30-1148-59

OPERATOR # 16

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Put SAND FILTERS BACK ON-LINE AT 11:30 AM

REPORTED BY: Kevin Lyon

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/10/16

TIME: 8:25 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HADZINA

DEP HOT LINE:

CASE # 16-01-10-0825-49

OPERATOR # 25

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BY PASSED SAND FILTERS DUE to HEAVY RAINFALL AT 8:15 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/12/16

TIME: 7:05 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-01-12-0706-39

OPERATOR # 25

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:
Peat Sand Filters Back on Line AT 6:45AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/3/16

TIME: 6:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 1602-03-1818-19

OPERATOR # 68

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By-pass Sandfilters do to High Flow "Heavy Rain Fall + Snow melt"

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/9/16

TIME: 6:10 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-02-09-0609-45

OPERATOR # 74

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK ON-LINE AT 6:00 AM

REPORTED BY: KEVIN LYNN

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/16/16

TIME: 2:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-02-16-1405-55

OPERATOR # 72

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
By Passed Sand Filters At 2:00pm Due to Heavy Rainfall & Snow melt

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/18/16

TIME: 6:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-02-18-0603-36

OPERATOR # 74

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK ON-LINE AT 6:00 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/25/16

TIME: 6:35 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 16-02-25-0636-53

OPERATOR # 35

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
By Passed Sand Filters Due to Heavy Rainfall
At 6:15 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/29/16

TIME: 8:35 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 16-02-29-0835-36

OPERATOR # 15

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

put Sand Filters Back on-line at 8:30 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7/21/16

TIME: 6:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-07-21-0637-07

OPERATOR # 74

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
Drained Clarifier # 2 for annual maintenance and Cleaning AT 6:30 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7/21/16

TIME: 2:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-07-21-1245-42

OPERATOR # 25

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

Pgt Clarifier # 2 BACK ONLINE AT 2:15 pm

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7/25/16

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 16-07-25-0826-03

OPERATOR # 59

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:
Drained Clarifier #1 for annual maintenance at 8:00 AM

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7/28/14

TIME: 1:45 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 16-07-28-1348-53

OPERATOR # 25

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Put Clanifien #1 Back on-Line at 1:45 pm

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/24/17

TIME: 6:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 17-01-24-06-1114

OPERATOR # 29

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By passed sand filters due to heavy rainfall. 1.52 inches of rain

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/26/17

TIME: 7:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 17-01-26-07-4822

OPERATOR # 59

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT:

Put Sand filters Back on-Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3-3-17

TIME: 9:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 17-03-03-1129-20

OPERATOR # 44

LOCATION OF INCIDENT: New Vernon Road

DESCRIPTION OF INCIDENT:
force main Break on New Vernon RD
Scott Rose Construction Repairing Force main
Break

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3-3-17

TIME: 5:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 17-03-03-1722-30

OPERATOR # 16

LOCATION OF INCIDENT: New Vernon Road

DESCRIPTION OF INCIDENT:

Force Main was Repaired & Back in service at 5:00 pm

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/31/17

TIME: 11:15 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: EO Hudzina

DEP HOT LINE:

CASE # 17-03-31-1130-40

OPERATOR # 15

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By Passed Sand Filters Due to Heavy Rainfall

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/8/17

TIME: 8:30 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: BO Hudzina

DEP HOT LINE: CASE # 17-04-08-0837-48

OPERATOR # 15

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: put Sand Filters BACK ON-LINE at 8:30 AM

REPORTED BY: Kevin

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/5/17

TIME: 11:20 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 17-05-05-1128-52

OPERATOR # 59

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
By-Passed Sand Filters Due to Heavy Rainfall

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/7/17

TIME: 8:20 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 17-05-07-0826-17

OPERATOR # 76

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
Put Sand filters Back on-Line

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5-15-17

TIME: 10:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUNZINA

DEP HOT LINE:

CASE # 17-05-15 1003-24

OPERATOR # 58

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT: By-pass Sand filters Due to Heavy Rain

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/16/17

TIME: 2:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 17-05-16-1410-10

OPERATOR # 68

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:
Put Sand filters Back on-line at 2:00 pm

REPORTED BY: Kevin Lynn

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10-29-17

TIME: 11:58 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUBZINA

DEP HOT LINE:

CASE # 17-10-29-2359-24

OPERATOR # 71

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT: Bypass Sandfilters Due To High Flows

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10-31-17

TIME: 7:43 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 17-10-31-0745-12

OPERATOR # 58

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

put Sandfilters back on line.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11-15-17

TIME: 10:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 17-11-15-1005-08

OPERATOR # 69

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By-pass Sandfilter TO INSTALL New pipe + pump #2.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11-15-17

TIME: 5:30 AM ~~PM~~

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 17-11-15-1738-56

OPERATOR # 67

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT:

put Sandfilters back on Line.

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 1/12/18

TIME: 11:10 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-01-12-1117-15

OPERATOR # 59

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By-pass sandfilters Due to Heavy Rain + Snow melt.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/14/18

TIME: 8:50 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-01-14-0855-13

OPERATOR # 59

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT:

Put Sandfilters back on-line. 8:50 am

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/7/18

TIME: 6:35 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-02-07-1842-51

OPERATOR # 75

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT: Bypass Sandfilters Due to Heavy Flow, Rain.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/9/18

TIME: 6:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-02-09-0620-00

OPERATOR # 68

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

put sand filters back online.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/11/18

TIME: 6:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-02-11-0608-58

OPERATOR # 74

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: BYPASS SANDFILTERS DUE TO HEAVY RAIN

REPORTED BY: VINNY TESTA.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/14/18

TIME: 6:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-02-14-0649-23

OPERATOR # 74

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT:

put Sandfilters Back on Line

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 2/25/18

TIME: 10:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-02-25-1020-56

OPERATOR # 74

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

BYPASS SANDFILTERS DUE TO HEAVY RAIN FLOW.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/27/18

TIME: 6:05 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-02-27-0611-17

OPERATOR # 68

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

PUT SANDFilters back online.

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3-2-18

TIME: 6:20 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-03-02-0630-41

OPERATOR # 59

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT: Bypass Sandfilters Due To Heavy Rain

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3-5-18

TIME: 6:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-03-05-0617-37

OPERATOR # 69

LOCATION OF INCIDENT: Treatment

DESCRIPTION OF INCIDENT:

Sand filters Back on line.

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3/29/18

TIME: 6:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-03-29-0647-40

OPERATOR # 69

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT:

Took So side water off to get Rebuilt on 3-20-18.

REPORTED BY: Vinny Pesta.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/6/18

TIME: 11.30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-04-09-0825-47

OPERATOR # 69

LOCATION OF INCIDENT: Treatment plant

DESCRIPTION OF INCIDENT:

Motor So. Side Back in Service

REPORTED BY: Vinny Testa

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/16/18

TIME: 9:20 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED Hudzina

DEP HOT LINE:

CASE # 18-04-16-0922-40

OPERATOR # 74

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

By-pass Sandfilters Due to Heavy Rain.

REPORTED BY: Vinny Testa.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/20/18

TIME: 8:50 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED. HUDZINA

DEP HOT LINE:

CASE # 18-04-20-0948-05

OPERATOR # 59

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: PLACE SAND FILTERS BACK ON-LINE.

REPORTED BY: J. Sehula

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4/26/18

TIME: 9:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED. HUDZINA

DEP HOT LINE:

CASE # 18-04-26 - 0929-37

OPERATOR # 89

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

EXCEEDED EFFLUENT LIMIT. OF B.O.D. KG/DAY <36.5 KG/DAY M/AVG. RESULTS. 27 KG/DAY M/AVG. LIMIT.

REPORTED BY: J. Tehula

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/24/18

TIME: 1121 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: Ed Hudzina

DEP HOT LINE:

CASE # 18-05-24-1121-32

OPERATOR # 59

LOCATION OF INCIDENT: Treatment Plant

DESCRIPTION OF INCIDENT:

Exceeded Effluent Limit of BOD Monthly Average Limit (< 326 Kg/day) and Weekly Average Limit (<44.8 Kg/day).

REPORTED BY: Peter Kwalen

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5-27-18

TIME: 6:46 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 18 0527190455

OPERATOR # 35

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

EXCEEDED EFFLUENT LIMIT.
BY-PASSING SAND FILTERS.

REPORTED BY: WALTER PINEDA.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/30/18

TIME: 2:30 AM/ PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED. HUDZINA

DEP HOT LINE:

CASE # 18-05-30-1428-47

OPERATOR # 44

LOCATION OF INCIDENT: TREATMENT PLANT.

DESCRIPTION OF INCIDENT:

SAND FILTERS BACK ON-LINE

REPORTED BY: J. TEKULA.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/20/18

TIME: 2:40 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED. HUDZINA

DEP HOT LINE:

CASE # 18-06-20-1435-52

OPERATOR # 71

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT:

TANK #1 NORTH AERATOR FAILURE, BEARING ON INSIDE BROKEN.

REPORTED BY: J. TEKULA

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/5/18

TIME: 10:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED. HUDZINA

DEP HOT LINE:

CASE # 18-08-05-1002-07

OPERATOR # 69

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: BY-PASS FILTERS DUE TO HEAVY FLOWS.

REPORTED BY: J. TEKULA.

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/7/18

TIME: 12:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-08-07-1000-13

OPERATOR # 69

LOCATION OF INCIDENT: TReatment Plant

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK TO NORMAL FLOW CONDITION

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/18/18

TIME: 10:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED. HUDZINA

DEP HOT LINE:

CASE # 18-08-18-1032-12

OPERATOR # 74

LOCATION OF INCIDENT: TREATMENT PLANT

DESCRIPTION OF INCIDENT: BY-PASS SAND FILTERS DUE TO HIGH FLOW.

REPORTED BY: J. TEKULA

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8/21/2018

TIME: 730 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-08-21-0723-28

OPERATOR # 58

LOCATION OF INCIDENT: LONG HILL TREATMENT PLANT

DESCRIPTION OF INCIDENT: PLACE SAND FILTERS BACK ON LINE TO NORMAL CONDITION

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 9/25

TIME: 7:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-09-26-0034-37

OPERATOR # 74

LOCATION OF INCIDENT: LONG HILL TREATMENT PLANT

DESCRIPTION OF INCIDENT: By Pass Sand Filters Due to high Flows and Heavy Rains

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/2/2018

TIME: 7:50 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-10-02-0752-54

OPERATOR # 58

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

PLACE SAND FILTERS BACK INTO OPERATIONAL MODE FROM PREVIOUS BY PASS

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/11/2018

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-10-12-0711-58

OPERATOR # 90

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: PLACE SAND FILTERS IN BYPASS MODE DUE TO HEAVY FLOWS. HEAVY RAINS

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 10/15/2018

TIME: 9:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-10-15-0928-30

OPERATOR # 74

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

PLACE SAND FILTERS BACK ON LINE TO NORMAL OPERATIONAL CONDITION

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/4/2018

TIME: 10:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-04-1033-08

OPERATOR # 69

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: BY PASS SAND FILTER DUE TO HEAVY FLOW TO THE PLANT.

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/6/2018

TIME: 7:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-06-0753-32

OPERATOR # 58

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

PLACED SAND FILTERS BACK ON LINE FROM BYPASS MODE.

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/25/2018

TIME: 12:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-25-1209-02

OPERATOR # 69

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

By-Pass Sand filters due to Heavy Rains / Flow

By-Pass performed @ 5:00 Am

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/29/2018

TIME: 8:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-29-0845-41

OPERATOR # 86

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:
Place Sand Filters back to Normal operational MODE from By-Pass

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/16/2018

TIME: 1:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-16-1253-36

OPERATOR # 44

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

By Pass Sand filters due to high flow to the plant.

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/20/2013

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-20-0819-08

OPERATOR # 60

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

PLACE SAND FILTERS BACK TO NORMAL OPERATIONAL MODE AT 7:00AM

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/13

TIME: 10:50 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-13-1055-33

OPERATOR # 69

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: BY PASS SAND FILTERS DUE TO HEAVY RAINS AND FLOW TO PLANT

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/14

TIME: 2:00 AM (PM)

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-14-1409-54

OPERATOR # 85

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: PLACE SAND FILTERS BACK TO NORMAL OPERATIONAL MODE

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/7/2018

TIME: 9:36 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-07-0942-59

OPERATOR # 69

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

BY PASS SAND FILTERS DUE TO HEAVY RAIN AND FLOW

BY PASS OCCURED 8PM ON 11/6/2018

REPORTED BY: JHIGGEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/8/2018

TIME: 9:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUZINA

DEP HOT LINE:

CASE # 18-11-08-0941-33

OPERATOR # 60

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: PLACE SAND FILTERS BACK ON LINE

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/3/2018

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: EW HURINA

DEP HOT LINE:

CASE # 18-12-03-1423-22

OPERATOR # 68

LOCATION OF INCIDENT: Long Hill STP- Collection System

DESCRIPTION OF INCIDENT: Valley Road and Mountain Ave overflowing manhole east of intersection due to high ground water table.

REPORTED BY: J. Higley

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: _____

TIME: _____ AM PM

ENFORCEMENT OFFICE
REPRESENTATIVE: _____

DEP HOT LINE:
CASE # _____

OPERATOR # _____

LOCATION OF INCIDENT: _____

DESCRIPTION OF INCIDENT:

_____

_____

_____

_____

_____

_____

_____

_____

REPORTED BY: _____

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/5/2018

TIME: 10:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-05-1115-27

OPERATOR # 74

LOCATION OF INCIDENT: LONG HILL STP. Collection System

DESCRIPTION OF INCIDENT: Valley Road and Mountain Ave.
≈ 15 gallons/hour flowed 50 hours
for an ≈ total of 750 gallons.

REPORTED BY: J Higley

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/17/2018

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-17-0816-01

OPERATOR # 58

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: BY PASS SAND FILTERS DUE TO HEAVY FLOW

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/19/2018

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-19-0803-50

OPERATOR # 74

LOCATION OF INCIDENT: LONGHILL STP

DESCRIPTION OF INCIDENT:

PUT SAND FILTERS BACK ON LINE FROM BY PASS MODE.

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/21/2018

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-21-0759-40

OPERATOR # 58

LOCATION OF INCIDENT: LONGHILL - STP

DESCRIPTION OF INCIDENT: BY-PASS SAND FILTERS DUE TO HEAVY RAIN AND FLOW. @ 7:00 AM

REPORTED BY: J HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 11/26/2018

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-26-1211-00

OPERATOR # 85

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: Place SAND FILTERS BACK ON LINE AT 8:00 AM.

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/29/2018

TIME: 10:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-28-1012-12

OPERATOR # 67

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT: By PASS SAND FILTERS DUE TO HEAVY RAIN AND HIGH FLOWS @ 10:00 AM

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12/31/2018

TIME: 8:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: ED HUDZINA

DEP HOT LINE:

CASE # 18-12-31-0808-57

OPERATOR # 60

LOCATION OF INCIDENT: LONG HILL - STP

DESCRIPTION OF INCIDENT:

Place Sand FILTERS Back into operational mode. @ 8:00 AM

REPORTED BY: J. HIGLEY

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12-31-18

TIME: 12:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 18-12-31-1231-33

OPERATOR # 58

LOCATION OF INCIDENT: Longhill STP

DESCRIPTION OF INCIDENT:

By-PASS The SAnd filters NSU left site At 12 And told US to Put BACK on line At 2:30 PM on 1-7-19

REPORTED BY: K. Shoudt

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 12-21-19

TIME: 8:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: _____

DEP HOT LINE:

CASE # 19-02-21-0821-23

OPERATOR # 15

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

By-pass the sand filters due to heavy flow, rain/snow @8:00am

REPORTED BY: M. Berger

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3-18-19

TIME: 9:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-03-18-0855-03

OPERATOR # 74

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:
Place Sand Filters back into operational Mode

REPORTED BY: M. Berger

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 3-21-19

TIME: 2:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-03-21-1425-13

OPERATOR # 44

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

Place Sand Filters in bypass due to Heavy Rainfall + High Flow @ 2:15pm 3-21-19

REPORTED BY: M. Berger

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4·14·19

TIME: 8:10 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: _____

DEP HOT LINE:

CASE # 19-04-14-0817-33

OPERATOR # _____

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

PLACE SAND FILTERS IN BYPASS DUE to heavy RAINFALL & High FLOWS @ 8:10 AM 4·14·19

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 4.29.19

TIME: 12:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-04-29-1229-39

OPERATOR # 74

LOCATION OF INCIDENT: Long hill STP

DESCRIPTION OF INCIDENT:

Place SAND Filters back into operational mode

REPORTED BY: J PAWlicki

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/5/2019

TIME: 6:15 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 1905 050836 23

OPERATOR # 58

LOCATION OF INCIDENT:

DESCRIPTION OF INCIDENT:

Bypass Sand Filters Due to Heavy Rain and high Flows @ 6:15 AM

REPORTED BY: B. Snyder

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5/20/14

TIME: 10:00 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-05-20-1011-16

OPERATOR # 74

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:
place Sand Filters Back Into Operational mode

REPORTED BY: B. Snyder

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 5-30-19

TIME: 9:45 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-05-30-0957-34

OPERATOR # 58

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:
Bypass Sand Filters due to heavy flow

REPORTED BY: MB

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6.6.19

TIME: 9:00 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: _____

DEP HOT LINE:

CASE # 19-05-30-0957-34

OPERATOR # 91

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

putting SAND Filters back in operation mode

REPORTED BY: JP

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/19/19

TIME: 6:25 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19061906 4039

OPERATOR # 73

LOCATION OF INCIDENT: Long Ann STP

DESCRIPTION OF INCIDENT:
Bypass Sand Filters Due to Heavy RAIN and High Flow

REPORTED BY: BS

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 6/26/19

TIME: 10:20 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-06-26-1029-35

OPERATOR # 94

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT: Putting Sand Filters Back in operation mode

REPORTED BY: BS

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7-18-19

TIME: 6:30 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-07-18-0648-58

OPERATOR # 59

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

Bypass Sand Filters due to heavy Rain + Flow @ 6:30am

REPORTED BY: MB

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7-26-19

TIME: 12:45 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-07-26-1259-38

OPERATOR # 83

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:
Placed sand filters back in operational mode

REPORTED BY: MB

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 7·31·19

TIME: 555 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-07-31-1759-34

OPERATOR # 85

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

BYPASS SAND FILTERS due to heavy RAIN and FLOW @ 550 PM

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8·1·19

TIME: 1100 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE: _____

DEP HOT LINE:

CASE # 19-08-01-1109-46

OPERATOR # 52

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

placed SAND FILTERS in operational mode

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8·7·19

TIME: 7:15 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: _____

DEP HOT LINE:

CASE # 19-08-07-1926-54

OPERATOR # 71

LOCATION OF INCIDENT: Long Hill STP

DESCRIPTION OF INCIDENT:

BYPASS SAND FILTERS due to heavy RAIN AND FLOW @ 7:15 PM

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8·9·19

TIME: 11:40 (AM) PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-08-07-1926-54

OPERATOR # 91

LOCATION OF INCIDENT: LONG HILL

DESCRIPTION OF INCIDENT:

placed sand filters back in operational mode.

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8 · 23 · 19

TIME: 8 40 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-08-23-0900-09

OPERATOR # 94

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

BYPASS SAND FILTERS DUE to HEAVY RAIN & FLOW @ 8:40 AM

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: 8·26·19

TIME: 200 AM PM

ENFORCEMENT OFFICE REPRESENTATIVE:

DEP HOT LINE:

CASE # 19-08-26-1428-36

OPERATOR # 67

LOCATION OF INCIDENT: LONG HILL STP

DESCRIPTION OF INCIDENT:

PLACED SAND FILTERS back in operational mode @ 2PM

REPORTED BY: J PAWLICKI

DEP CONTACTS RELATING TO SPILLS , OVERFLOWS AND TREATMENT PRBLEMS

DATE REPORTED: _____

TIME: _____ AM PM

ENFORCEMENT OFFICE REPRESENTATIVE: _____

DEP HOT LINE:

CASE # _____

OPERATOR # _____

LOCATION OF INCIDENT: _____

DESCRIPTION OF INCIDENT:

_____

_____

_____

_____

_____

_____

_____

_____

REPORTED BY: _____